



Inspection report

Date: 6/3/2022	Work Order:	Weather: Dry	Surveyed By: Steven Bucklin	Certificate Number: U-0819-70306510	Pipe Segment Ref.: MH060001-MH060002
Year laid:	Pre-cleaning: Heavy Cleaning	Direction: Upstream	Pipe Joint Length:	Total Length:	Length Surveyed:

City: City of Superior	Drainage Area:	Upstream MH: MH060002
Street: BELKNAP	Media Label: 1111	Up Rim to Invert: 0.0
Location Code: Easement/Right of way	Flow Control: Lift Station	Downstream MH: MH060001
Location Details: SOUTH OF BELKNAP, BY THE RAILROAD	Sheet Number: 16	Down Rim to Invert: 0.0
Pipe shape: Circular	Sewer Use: Combined Pipe	Total gallons used: 0.0
Pipe size: 15	Sewer Category: SEC	Joints passed: 0
Pipe material: Reinforced Concrete Pipe	Purpose: Routine Assessment	Joints failed: 0
Lining Method: None	Owner: City of Superior	

Additional Info:

1:2800	Distance	Code	Observation	Counter	Photo	Grade		
MH060001								
	0.0	AMH	Manhole / MH060001	00:00:01	MH060001 -MH06000 2_2e170b			
	0.0	MWL	Water Level, 10% of the vertical dimension	00:01:04	MH060001 -MH06000 2_fbc33ad			
	1.6	S01 RMJ	Roots Medium Joint from 9 o'clock to 3 o'clock, 35% of cross sectional area, Start, within 8 inch	00:01:51	MH060001 -MH06000 2_df530c5			
	76.2	JSM	Joint Separated Medium	00:06:07	MH060001 -MH06000 2_6b151a	S3		
	294.2	IGJ	Infiltration Gusher Joint at 3 o'clock, within 8 inch	00:19:16	MH060001 -MH06000 2_7c5aa97	M5		
	297.9	IRJ	Infiltration Runner Joint at 3 o'clock, within 8 inch	00:22:33	MH060001 -MH06000 2_8022b4	M4		
	314.1	IGJ	Infiltration Gusher Joint from 2 o'clock to 4 o'clock, within 8 inch	00:24:28	MH060001 -MH06000 2_785a60c	M5		
	370.8	F01 RMJ	Roots Medium Joint from 9 o'clock to 3 o'clock, 35% of cross sectional area, Finish, within 8 inch	00:28:41	MH060001 -MH06000 2_4582de	M3		
	370.9	AMH	Manhole / MH060002	00:30:16	MH060001 -MH06000 2_f98effd6			
MH060002								
QSR	QMR	QOR	SPR	MPR	OPR	SPRI	MPRI	OPRI
3100	5241	5241	3.0	236.0	239.0	3.0	3.1	3.1