

# PACPO Inspection Form

**Surveyors Name** David Sigfrids **Certificate Number** U-605-2213 **System Owner**  **Survey Customer**  **Drainage Area**  **Sheet No.** 1 of 1  
**P/O No.**  **Pipe Segment Reference** MH010021-LH010022 **Date** 2023/07/17 **Time** 07:09 **Location (Street Name and Number)**  **City of Superior**  **Locality (City)**   
**Further Location Details**  **Upstream Manhole Number** LH010022 **Rim to Invert**  **Grade to Invert**  **Rim to Grade**   
**Downstream Manhole Number** MH010021 **Rim to Invert**  **Grade to Invert**  **Rim to Grade**  **Use of Sewer**  **Direction**  **Flow Control**  **Height** 6 in.  
**Width**  **Shape** Circular **Material** Reinforced Concrete F **Ln. Method**  **Joint Length**  **Total Length** 344.1 ft. **Length Surveyed** 344.1 ft. **Year Laid**  **Year Rehab.**  **Tape/Media No.** 1134  
**Purpose**  **Sewer Category**  **Pre-Cleaning**  **Cleaned**  **Weather**  **Location Code**  **Additional Information**

Distance (Feet)	Video Ref.	Group	Description	Modifier	Cont. Defect	Inches 1st	Inches 2nd	%	Joint	At/From	To	Image Ref.	Remarks
0.00		Access Point	Manhole						<input type="checkbox"/>				LH010022
0.00		Miscellaneous	Water Level				40		<input type="checkbox"/>				
65.20		Miscellaneous	Water Level	Sag			70		<input type="checkbox"/>				
73.10		Tap	Factory Made	Capped	4	4			<input type="checkbox"/>	2			
75.50		Tap	Factory Made	Capped	4	4			<input type="checkbox"/>	10			
175.00		Tap	Factory Made	Capped	4	4			<input type="checkbox"/>	2			
178.00		Tap	Factory Made	Capped	4	4			<input type="checkbox"/>	10			
232.60		Miscellaneous	Water Level	Sag			40		<input type="checkbox"/>				
240.10		Tap	Factory Made	Capped	4	4			<input type="checkbox"/>	2			
242.10		Tap	Factory Made	Capped	4	4			<input type="checkbox"/>	10			
270.70		Tap	Factory Made	Capped	4	4			<input type="checkbox"/>	10			
317.00		Tap	Factory Made	Capped	4	4			<input type="checkbox"/>	1			
319.10		Tap	Factory Made	Capped	4	4			<input type="checkbox"/>	10			
344.10		Miscellaneous	Survey Abandoned						<input type="checkbox"/>				debris
344.10		Access Point	Manhole						<input type="checkbox"/>				debris