

PACP® Inspection Form

Surveyors Name Mickey Webster	Certificate Number T-605-2280	System Owner City of Superior	Survey Customer City of Superior	Drainage Area District 01	Sheet No. 1 of 1				
P/O No.	Pipe Segment Reference ST010151-ST010152	Date 2007/11/09	Time 09:35	Location (Street Name and Number) Hughitt / 1st	Locality (City) Superior				
Further Location Details	Upstream Manhole Number ST010152	Rim to Invert	Grade to Invert	Rim to Grade					
Downstream Manhole Number ST010151	Rim to Invert	Grade to Invert	Rim to Grade	Use of Sewer Stormwater	Direction Downstream	Flow Control	Height 36 in.		
Width	Shape Circular	Material Concrete Pipe (non-re	Ln. Method	Joint Length 456.2 ft.	Total Length 456.2 ft.	Length Surveyed 456.2 ft.	Year Laid	Year Rehab.	Tape/Media No. 386
Purpose Routine Assessment	Sewer Category	Pre-Cleaning Jetting	Cleaned	Weather Snow	Location Code	Additional Information			

Distance (Feet)	Video Ref.	Group	Description	Modifier	Cont. Defect	Inches 1st	Inches 2nd	%	Joint	At/From	To	Image Ref.	Remarks
0.00		Access Point	Manhole						<input type="checkbox"/>				ST010152
0.00		Miscellaneous	Water Level					0	<input type="checkbox"/>				
10.90		Tap	Factory Made	Capped		6			<input type="checkbox"/>	12			
43.60		Line	Right						<input type="checkbox"/>				
206.70		Tap	Factory Made	Capped		6			<input type="checkbox"/>	12			
448.40		Miscellaneous	Water Level					85	<input type="checkbox"/>				
456.20		Miscellaneous	Survey Abandoned						<input type="checkbox"/>				High Water
456.20		Access Point	Manhole						<input type="checkbox"/>				High Water