

PACP® Inspection Form

Surveyors Name Certificate Number System Owner Survey Customer Drainage Area Sheet No.
 Mickey Webster T-605-2280 City of Superior City of Superior District 05 1 of 1
 P/O No. Pipe Segment Reference Date Time Location (Street Name and Number) Locality (City) Superior
 Further Location Details Upstream Manhole Number Rim to Invert Grade to Invert Rim to Grade
 Downstream Manhole Number Rim to Invert Grade to Invert Rim to Grade MH050310 MH050311
 Width Shape Material L.n. Method Joint Length Total Length Length Surveyed Year Laid Year Rehab. Tape/Media No.
 Circular Reinforced Concrete F 399 ft. 399 ft. 399 ft. 409
 Purpose Sewer Category Pre-Cleaning Cleaned Weather Location Code Additional Information
 Routine Assessment Not Known Dry

Distance (Feet)	Video Ref.	Group	Description	Modifier	Cont. Defect	Inches 1st	Inches 2nd	%	Joint	AV From	To	Image Ref.	Remarks
0.00		Access Point	Manhole						<input type="checkbox"/>				MH050311
0.00		Miscellaneous	Water Level				10		<input type="checkbox"/>				
24.50			Infiltration	Weeper					<input type="checkbox"/>	10	2		
37.10			Infiltration	Dripper					<input type="checkbox"/>	2	5		
105.80			Infiltration	Weeper					<input type="checkbox"/>	8	10		
113.90			Infiltration	Weeper					<input type="checkbox"/>	7	10		
117.90			Infiltration	Weeper					<input type="checkbox"/>	11	1		
126.70			Infiltration	Dripper					<input type="checkbox"/>	7	10		
130.90			Infiltration	Weeper					<input type="checkbox"/>	7	9		
182.90			Infiltration	Weeper					<input type="checkbox"/>	4	5		
186.70			Infiltration	Weeper					<input type="checkbox"/>	11	1		
194.40			Infiltration	Weeper					<input type="checkbox"/>	8	11		
206.90			Infiltration	Weeper					<input type="checkbox"/>	7	9		
239.00			Infiltration	Weeper					<input type="checkbox"/>	8	4		
242.90			Infiltration	Weeper					<input type="checkbox"/>	2	5		
251.60			Infiltration	Weeper					<input type="checkbox"/>	2	5		
255.70			Infiltration	Dripper					<input type="checkbox"/>	2	5		
259.70			Infiltration	Weeper					<input type="checkbox"/>	8	4		
263.90			Infiltration	Weeper					<input type="checkbox"/>	3	5		
271.80			Infiltration	Weeper					<input type="checkbox"/>	2	5		

Distance (Feet)	Video Ref.	Group	Description	Modifier	Cont. Defect	Inches 1st	Inches 2nd	%	Joint	At/From	To	Image Ref.	Remarks
279.70		Infiltration	Weeper						<input type="checkbox"/>	8	4		
284.70		Infiltration	Weeper						<input type="checkbox"/>	7	10		
288.70		Infiltration	Weeper		S01				<input type="checkbox"/>	8	4		
290.70		Surface Damage	Reinforcement Visible						<input type="checkbox"/>	1	3		
308.50		Tap	Break-in	Intruding		6	1		<input type="checkbox"/>	11			
314.70		Infiltration	Weeper		F01				<input type="checkbox"/>	8	4		
325.10		Infiltration	Weeper						<input type="checkbox"/>	9	3		
329.40		Infiltration	Weeper						<input type="checkbox"/>	8	4		
353.70		Infiltration	Dripper						<input type="checkbox"/>	7	10		
361.90		Infiltration	Weeper						<input type="checkbox"/>	7	9		
365.70		Infiltration	Weeper						<input type="checkbox"/>	9	10		
370.10		Infiltration	Weeper						<input type="checkbox"/>	2	5		
377.90		Infiltration	Weeper						<input type="checkbox"/>	3	5		
399.00		Access Point	Manhole						<input type="checkbox"/>				MH050310