



## Inspection report

Date: <b>6/16/2022</b>	Work Order:	Weather: <b>Dry</b>	Surveyed By: <b>Steven Bucklin</b>	Certificate Number: <b>U-0819-70306510</b>	Pipe Segment Ref.: <b>MH050312-MH05312A</b>
Year laid:	Pre-cleaning: <b>Light Cleaning</b>	Direction: <b>Upstream</b>	Pipe Joint Length:	Total Length:	Length Surveyed:

City: <b>Superior</b>	Drainage Area:	Upstream MH: <b>MH05312A</b>
Street: <b>HILL</b>	Media Label: <b>1115</b>	Up Rim to Invert: <b>0.0</b>
Location Code: <b>Local rural streets with light traffic</b>	Flow Control: <b>Lift Station</b>	Downstream MH: <b>MH050312</b>
Location Details:	Sheet Number:	Down Rim to Invert: <b>0.0</b>
Pipe shape: <b>Circular</b>	Sewer Use: <b>Sanitary Sewage Pipe</b>	Total gallons used: <b>0.0</b>
Pipe size: <b>15</b>	Sewer Category: <b>SEC</b>	Joints passed: <b>0</b>
Pipe material: <b>Reinforced Concrete Pipe</b>	Purpose: <b>Routine Assessment</b>	Joints failed: <b>0</b>
Lining Method: <b>None</b>	Owner: <b>City of Superior</b>	

Additional Info:

1:1780	Distance	Code	Observation	Counter	Photo	Grade		
<b>MH050312</b>								
	0.0	AMH	Manhole / MH050312	00:00:01	MH050312 -MH05312 A_bb74fa2			
	0.0	MWL	Water Level, 15% of the vertical dimension	00:01:32	MH050312 -MH05312 A_6977c2			
	3.4	S01	SAP	00:02:35	MH050312 -MH05312 A_ccb846f			
	174.8	DAE	Deposits Attached Encrustation, 5% of cross sectional area from 9 o'clock to 12 o'clock, within 8 inch	00:14:19	MH050312 -MH05312 A_f015327	M2		
	174.8	IWJ	Infiltration Weeper Joint from 11 o'clock to 12 o'clock, within 8 inch	00:14:29	MH050312 -MH05312 A_4ca342	M2		
	215.2	IWJ	Infiltration Weeper Joint from 11 o'clock to 1 o'clock, within 8 inch	00:18:27	MH050312 -MH05312 A_65554b	M2		
	215.2	DAE	Deposits Attached Encrustation, 5% of cross sectional area from 9 o'clock to 3 o'clock, within 8 inch	00:18:40	MH050312 -MH05312 A_279a0b	M2		
	219.3	DAE	Deposits Attached Encrustation, 5% of cross sectional area from 8 o'clock to 3 o'clock, within 8 inch	00:19:44	MH050312 -MH05312 A_fd74019	M2		
	234.5	F01	SAP	00:20:58	MH050312 -MH05312 A_757706	S3		
	235.8	AMH	Manhole / MH05312A	00:23:37	MH050312 -MH05312 A_7b1d61			
<b>MH05312A</b>								
QSR	QMR	QOR	SPR	MPR	OPR	SPRI	MPRI	OPRI
3H00	2500	3H25	138.0	10.0	148.0	3.0	2.0	2.9