

CITY OF SUPERIOR WI.  
SANITARY SEWERS  
TELEVISED BY RL SHAW COMPANY  
DULUTH MN. 55803  
Television Inspection Report

Line Segment Number  
M.H.03A307- M.H. 03A306

Inspection Date... 02/26/1997  
Inspection Time... 09:00 AM  
Operator ID..... DICK  
Precipitation..... None  
Ground Condition.. Dry  
Type of Surface... Paved  
Pipe Material..... Concrete  
Pipe Diameter..... 21 (in)

Depth of Pipe..... 25.0 (ft)  
Length Between Joints.. 3.0 (ft)  
Length of Pipe..... 367.0 (ft)  
Test Pressure..... (psi)  
Tape Number..... S-005 #110  
Tape Start Index.....  
Tape End Index..... 0-835

*Fair condition*

Street Name..... E.2ND. STREET SANITARY SEWER  
Comments..... LT ROOTS, MINERAL DEPOSTS, SAGS, PIPE LOOKS GOOD.

FTG	Observation Code/Description	Obsvd		Rep Len	Tape WO SR	Index	Pic No.	Jnt No.	T R	Grout Amt.
		Inflt (gpm)	O C							
0.0	01 UPSTREAM MANHOLE									
70.0	22 MINERAL DEPOSITS									
92.0	22 MINERAL DEPOSITS									
	13 LIGHT ROOTS									
128.0	13 LIGHT ROOTS									
138.0	22 MINERAL DEPOSITS									
150.0	22 MINERAL DEPOSITS									
165.0	33 SAG									
208.0	22 MINERAL DEPOSITS									
211.0	33 SAG									
255.0	09 CAMERA SUBMERGED									
367.0	02 DOWNSTREAM MANHOLE									
Line Segment Totals		0.00		0						0.0