

PACP© Inspection Form

Surveyors Name Mickey Webster	Certificate Number T-605-2280	System Owner City of Superior	Survey Customer City of Superior	Drainage Area District 3A	Sheet No. 1 of 1				
P/O No.	Pipe Segment Reference MH3A0307-MH3A307A	Date 2008/06/16	Time 12:04	Location (Street Name and Number) Hill Ave / 25th / 26th	Locality (City) Superior				
Further Location Details			Upstream Manhole Number MH3A307A	Rim to Invert	Grade to Invert	Rim to Grade			
Downstream Manhole Number MH3A0307	Rim to Invert	Grade to Invert	Rim to Grade	Use of Sewer Sanitary	Direction Downstream	Flow Control	Height 15 in.		
Width	Shape Circular	Material Reinforced Concrete F	Ln. Method	Joint Length 125.3 ft.	Total Length 125.3 ft.	Length Surveyed 125.3 ft.	Year Laid	Year Rehab.	Tape/Media No. 408
Purpose Routine Assessment	Sewer Category	Pre-Cleaning Not Known	Cleaned	Weather Dry	Location Code	Additional Information			

Distance (Feet)	Video Ref.	Group	Description	Modifier	Cont. Defect	Inches 1st	Inches 2nd	%	Joint	At/From	To	Image Ref.	Remarks
46.30		Tap	Break-in	Intruding		6	1		<input type="checkbox"/>	10			
46.40		Infiltration	Weeper						<input type="checkbox"/>	7	10		
47.50		Infiltration	Weeper						<input type="checkbox"/>	4	5		
76.10		Infiltration	Weeper						<input type="checkbox"/>	4	5		
117.30		Crack	Longitudinal						<input type="checkbox"/>	7			
125.30		Access Point	Manhole						<input type="checkbox"/>				MH3A0307