

PACP® Inspection Form

Surveyors Name Mickey Webster
 Certificate Number T-605-2280
 System Owner City of Superior
 Survey Customer City of Superior
 Drainage Area District 01
 Sheet No. 1 of 1

P/O No. CB01001B-CB01001C
 Pipe Segment Reference CB01001B-CB01001C
 Date 2008/10/24
 Time 13:10
 Location (Street Name and Number) 3rd ST / Tower
 Locality (City) Superior

Further Location Details

Downstream Manhole Number CB01001C
 Rim to Invert Grade to Invert Rim to Grade

Width Circular
 Shape Circular
 Material Reinforced Concrete F
 L.n. Method

Purpose Routine Assessment
 Sewer Category Pre-Cleaning
 Cleaned

Joint Length 31.9 ft.
 Total Length 31.9 ft.
 Length Surveyed 31.9 ft.

Use of Sewer Stormwater
 Direction Upstream
 Flow Control

Year Laid Year Rehab.

Height 15 in.
 Tape/Media No. 438

Location Code Easement/Right of W
 Additional Information

Distance (feet)	Video Ref.	Group	Description	Modifier	Cont. Defect	Inches 1st	Inches 2nd	%	Joint	AV From	To	Image Ref.	Remarks
0.00		Access Point	Manhole						<input type="checkbox"/>				CB01001B
0.00		Miscellaneous	Water Level				0		<input type="checkbox"/>				
31.90		Miscellaneous	Survey Abandoned						<input type="checkbox"/>				Debris in line
31.90		Access Point	Manhole						<input type="checkbox"/>				Debris in line