


- NOTES:
1. THE ABANDONED 12" GRAVITY SEWER LINES SHALL BE FILLED WITH SAND OR CEMENT GROUT.
 2. SEE "STANDARD SPECIFICATIONS FOR SEWER AND WATER CONSTRUCTION IN WISCONSIN" FILE NO. 44 FOR CONCRETE BUTTRESSING OF BENDS.
 3. FOR MANHOLES, UPSTREAM PIPE INVERTS ARE NOTED.
 4. VERIFY LOCATION OF ALL UNDERGROUND UTILITIES. REPAIR ANY DAMAGED LINES AS REQUIRED.



Half Size

