

PACP® Inspection Form

Surveyors Name Mickey Webster	Certificate Number T-605-2280	System Owner City of Superior	Survey Customer City of Superior	Drainage Area District 06	Sheet No. 1 of 1				
P/O No.	Pipe Segment Reference MH060517 -MH060641 <i>Lackawanna</i>	Date 2008/02/27	Time 10:38	Location (Street Name and Number) Belknap & Lackawanna	Locality (City) Superior				
Further Location Details		Upstream Manhole Number MH060641	Rim to Invert	Grade to Invert	Rim to Grade				
Downstream Manhole Number MH060517	Rim to Invert	Grade to Invert	Rim to Grade	Use of Sewer Combined	Direction Downstream	Flow Control	Height 8 in.		
Width	Shape Circular	Material Clay Tile	Ln. Method	Joint Length 26.5 ft.	Total Length 26.5 ft.	Length Surveyed 26.5 ft.	Year Laid	Year Rehab.	Tape/Media No. 394
Purpose	Sewer Category	Pre-Cleaning No Pre-Cleaning	Cleaned	Weather	Location Code	Additional Information			

Distance (Feet)	Video Ref.	Group	Description	Modifier	Cont. Defect	Inches 1st	Inches 2nd	%	Joint	At/From	To	Image Ref.	Remarks
0.00		Access Point	Manhole						<input type="checkbox"/>				MH060641
0.00		Miscellaneous	Water Level					5	<input type="checkbox"/>				
25.50		Miscellaneous	Water Level	Sag				20	<input type="checkbox"/>				
26.50		Access Point	Manhole						<input type="checkbox"/>				debris