

PACP® Inspection Form

Surveyors Name David Sigfrids **Certificate Number** U-605-2213 **System Owner** City of Superior **Survey Customer** City of Superior **Drainage Area** **Sheet No.** 1 of 1
P/O No. MH010171-MH010010 **Date** 2023/06/28 **Time** 09:54 **Location (Street Name and Number)** 3rd Street & Tower **Locality (City)** Superior **Rim to Invert** **Grade to Invert** **Rim to Grade**
Further Location Details **Upstream Manhole Number** ~~MH010171~~ MH010171 **Direction** Upstream **Flow Control** 10 in.
Downstream Manhole Number ~~MH010010~~ MH010010 **Rim to Invert** **Grade to Invert** **Rim to Grade** **Use of Sewer** Sanitary **Length Surveyed** 335.4 ft. **Year Laid** **Year Rehab.** 1133
Width **Shape** Circular **Material** Clay Tile **Ln. Method** **Joint Length** 335.4 ft. **Total Length** 335.4 ft. **Location Code** **Additional Information**
Purpose **Sewer Category** **Pre-Cleaning** **Cleaned** **Weather**

Distance (Feet)	Video Ref.	Group	Description	Modifier	Cont. Defect	Inches 1st	Inches 2nd	%	Joint	At/ From	To	Image Ref.	Remarks
0.00		Access Point	Manhole						<input type="checkbox"/>				MH010010
0.00		Miscellaneous	Water Level				5		<input type="checkbox"/>				
5.70		Joint	Offset	Medium					<input type="checkbox"/>				
11.00		Joint	Offset	Medium					<input type="checkbox"/>				
13.80		Miscellaneous	Material Change						<input type="checkbox"/>				Clay to RCP
47.80		Deposits	Attached	Encrustation			5		<input type="checkbox"/>	2	9		
63.50		Deposits	Attached	Encrustation			5		<input type="checkbox"/>	2	6		
63.80		Tap	Factory Made	Capped		4			<input type="checkbox"/>	2			
66.20		Tap	Factory Made	Capped		4			<input type="checkbox"/>	10			
82.30		Tap	Factory Made	Capped		4			<input type="checkbox"/>	10			
137.30		Tap	Factory Made	Capped		4			<input type="checkbox"/>	2			
139.10		Tap	Factory Made	Capped		4			<input type="checkbox"/>	10			
167.10		Tap	Factory Made	Capped		4			<input type="checkbox"/>	10			
192.00		Tap	Factory Made	Capped		4			<input type="checkbox"/>	10			
240.30		Tap	Factory Made	Capped		4			<input type="checkbox"/>	10			
262.10		Tap	Factory Made	Capped		4			<input type="checkbox"/>	2			
264.30		Tap	Factory Made	Capped		4			<input type="checkbox"/>	10			
290.50		Tap	Factory Made	Capped		4			<input type="checkbox"/>	2			
292.20		Tap	Factory Made	Capped		4			<input type="checkbox"/>	10			
335.40		Miscellaneous	Survey Abandoned						<input type="checkbox"/>				Camera under water

Distance (Feet)	Video Ref.	Group	Description	Modifier	Cont. Defect	Inches 1st	Inches 2nd	%	Joint	At/From	To	Image Ref.	Remarks
335.40		Access Point	Manhole						<input type="checkbox"/>				Cam under water