

PACP® Inspection Form

Surveyors Name David Sigfrids **Certificate Number** U-605-2213 **System Owner** City of Superior **Survey Customer** City of Superior **Drainage Area** **Sheet No.** 1 of 1
P/O No. MH02437G-MH060001 **Date** 2023/09/05 **Time** 13:17 **Location (Street Name and Number)** 15th/16thOaks **Locality (City)** Superior **Rim to Invert** **Grade to Invert** **Rim to Grade**
Further Location Details **Upstream Manhole Number** MH060001 **Use of Sewer** Sanitary **Direction** Downstream **Flow Control** **Height** 15 in.
Downstream Manhole Number MH02437G **Rim to Invert** **Grade to Invert** **Rim to Grade** **Joint Length** **Total Length** 267.8 ft. **Length Surveyed** 267.8 ft. **Year Laid** **Year Rehab.** **Tape/Media No.** 1141
Width **Shape** Circular **Material** Reinforced Concrete F **Ln. Method** **Joint Length** **Total Length** 267.8 ft. **Length Surveyed** 267.8 ft. **Year Laid** **Year Rehab.** **Tape/Media No.** 1141
Purpose **Sewer Category** **Pre-Cleaning** **Cleaned** **Weather** **Location Code** **Additional Information**

Distance (Feet)	Video Ref.	Group	Description	Modifier	Cont. Defect	Inches 1st	Inches 2nd	%	Joint	At/From	To	Image Ref.	Remarks
0.00		Access Point	Manhole						<input type="checkbox"/>				MH060001
0.00		Miscellaneous	Water Level				30		<input type="checkbox"/>				
1.80		Roots	Fine	Joint	S01				<input checked="" type="checkbox"/>	7	5		
20.20		Roots	Fine	Joint	F01				<input checked="" type="checkbox"/>	7	5		
194.20		Roots	Fine	Joint					<input checked="" type="checkbox"/>	10			
206.60		Roots	Fine	Joint					<input checked="" type="checkbox"/>	1			
219.40		Roots	Fine	Joint					<input checked="" type="checkbox"/>	1			
223.00		Roots	Fine	Joint					<input checked="" type="checkbox"/>	10	2		
238.80		Miscellaneous	Water Level				80		<input type="checkbox"/>				
267.80		Access Point	Manhole						<input type="checkbox"/>				MH02437G